



DATE Mar. 6, 2012

NO. SBT-02954A

Your Ref No. SBT-02954AJZ

Messrs. _____

SPECIFICATION

FOR

6.6kV EP RUBBER INSULATED AND POLYCHLOROPRENE

SHEATHED FLAT TYPE FLEXIBLE CABLE

(F-3PNCT-JZ)

Project : _____

T. Fujita

Prepared by

T.FUJITA

Design & Engineering Group
Engineering Department
Industrial & Telecommunication Cable Division

R. Tonegawa

Approved by

R.TONEGAWA

Group Manager
Design & Engineering Group
Engineering Department
Industrial & Telecommunication Cable Division

Fujikura Ltd.

CONSTRUCTION DATA

Type of cable		F-3PNCT-JZ	
Rated voltage (kV)		6.6	
Number of core		3 (Power)	1 (Earth)
Conductor * TA	Nominal sectional area (mm ²)	240	50
	No. and dia. of wire (No./mm)	37/33/0.5	19/22/0.4
	Approx. dia. of conductor (mm)	23.3	10.9
Thick. of semi-conductive layer (mm)		-	
Thick. of insulation (mm)		5.5	2.1
Approx. thick. of semi-conductive tape (mm)		-	
Flexible copper-fibrous yarn braid (Copper Fibrous yarn)		7/0.26 Yarn	- -
Approx. thick. of reinforcement (mm)		0.5	0.5
Colour code		Red, White, Blue	Green
Thick. of sheath (mm)		8.0	
Overall dimension (Height x Width)	Standard (mm)	51.0 X 138.4	
	Maximum (mm)	53.6 X 145.3	
Approx. net weight (kg/km)		14870	
Testing voltage (V/min.)		17000/10	3000/1
Max. conductor resistance at 20°C (Ω/km)		0.0817	0.393
Min. insulation resistance at 20°C (MΩ-km)		300	300

* TA : Tinned annealed copper wire

