



DATE Apr. 27, 2010

NO. SBT-03363

Messrs. _____

SPECIFICATION

FOR _____

6.6kV EP RUBBER INSULATED AND POLYCHLOROPRENE

SHEATHED FLAT TYPE FLEXIBLE CABLE

(F-3PNCT)

Project : _____

Prepared by

Y.OI

Senior Design Engineer
Design & Engineering Group
Engineering Department
Industrial & Telecommunication Cable Divisio


Approved by

R.TONEGAWA

Group Manager
Design & Engineering Group
Engineering Department
Industrial & Telecommunication Cable Division

Fujikura Ltd.

CONSTRUCTION DATA (1)

Type of cable		F-3PNCT
Rated voltage	(kV)	6.6
Number of core		3
Conductor * TA	Nominal sectional area	(mm ²) 22
	No. and dia. of wire	(No. /mm) 7/20/0.45
	Approx. dia. of conductor	(mm) 7.0
Thick. of semi-conductive layer		(mm) 
Thick. of insulation		(mm) 5.0
Approx. thick. of semi-conductive tape		(mm) 0.4
Flexible copper-fibrous yarn braid (Copper Fibrous yarn)		(7/0.26 Yarn)
Approx. thick. of reinforcement		(mm) 0.5
Colour code		Red, White, Blue
Thick. of sheath		(mm) 5.2
Overall dimension (Height x Width)	Standard	(mm) 28.3 X 65.1
	Maximum	(mm) 29.7 X 68.4
Approx. net weight		(kg/km) 2950
Testing voltage		(V/10 min.) 17000
Max. conductor resistance at 20°C		(Ω/km) 0.892
Min. insulation resistance at 20°C		(MΩ-km) 500

* TA : Tinned annealed copper wire

